


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Direktor: Prof. Dr. rer. nat. L. Dunemann

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.

Hygiene-Institut, UMWELT Postfach 10 12 55 · 45812 Gelsenkirchen



Rotthauer Str. 21
45879 Gelsenkirchen

Telefon (0209) 9242-0
Telefax (0209) 9242-222
Internet www.hyg.de

Reference: W-314756e-19-Ho
Before: W-260483e-15-Ho
Contact person: Dipl.-Ing. (FH) S. Horn

Test – certificate

(Transcription of certificate W-260483e-15-Ho)

hygiene – conformity check to the design requirements of selected technical guidelines

Test institute: Hygiene Institut des Ruhrgebiets
Institut für Umwelthygiene und Toxikologie
Rotthauer Straße 21
49879 Gelsenkirchen

Test object: HVAC system „MYHB“

Manufacturer: SEM srl
Via Enrico Mattei n.59
Nucleo Industriale A
86039 Termoli (CB)
Italy

Basis of the examination: ✓ VDI 6022, Blatt 1 (01/2018)
✓ SWKI VA104-01 (01/2019)
✓ DIN 1946, Teil 4 (09/2018)

Validity period: 5 years 06/2019 – 06/2024

Test report: W-314756-19-Ho



In conclusion it can be stated that the examined HVAC system „MYHB“, as specified in the test report W-314756-19-Ho, is in compliance with the above mentioned regulations.

(Priv.-Doz. Dr. G.-J. Tuschewitzki
Head of the Department of Water Hygiene
and Environmental Microbiology

(Dipl.-Ing. (FH) S. Horn)
Department of Water Hygiene
and Environmental Microbiology

issued 27.06.2019, Gelsenkirchen

In the context of the hygiene - conformity check the hygienic relevant requirements of the above-mentioned guidelines were tested. Requirements of other guidelines, which refer to the above-mentioned guidelines, were not tested. Furthermore, the hygiene - conformity check does not cover toxicological and sensorial tests of the used materials.

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V., Vereinsregister: VR 519 Amtsgericht Gelsenkirchen, USt.-ID: DE125018356

Vorstand: Prof. Dr. Werner Schlake (Vors.), Prof. Dr. Jürgen Kretschmann, Dr. Emanuel Grün, Dr. Dirk Waider, Prof. Dr. Lothar Dunemann (geschäftsführ. Vorstand)